

REMOVEABLE ORNAMENTAL
POLE TOP FINIAL

LPS LUMINAIRE
(WATTAGE AS SPECIFIED)

PHOTO-CONTROL OR
SHORTING CAP WITH LOCKING
RECEPTACLE AS REQUIRED

HPS LUMINAIRE
(WATTAGE AS SPECIFIED)

GALVANIZED MASTARM
(TYPE C-8 STANDARD)

STANDARD (TYPE 10-B, GALVANIZED
FINISH STANDARD)

POLE LABEL

GROUT

#3 1/2 PULL BOX

FINISH GRADE

HANDHOLE

P.C.C. FOUNDATION CAP

P.C.C. FOUNDATION

APPROVED BY

AWJ

DATE

3/3/92

TYPICAL ELECTROLIER
LOW PRESSURE SODIUM
HIGH PRESSURE SODIUM

DEPARTMENT OF PUBLIC WORKS



DRAWING
NO.

E-09